

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0328:119

Page 1 of 1

**CATEGORY:** Audible Device

**LISTEE:** Potter, 2081 Craig Road, St. Louis MO 63146  
Contact: \*Brad Serangeli (314) 8788-4321

**DESIGN:** Models PBD126, PBD128, PBD1210, PBD246, PBD248, PBD2410, PBA246, PBA248, PBA2410, PBA1206, PBA1208 and PBA12010 vibrating bells. Suitable for outdoor use when used with Model BBK-1 backbox. Models are AC or DC powered and available in 6", 8" and 10". Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** PBD-126, -128, -1210: 12 VDC  
PBD-246, -248, -2410: 24 VDC  
PBA-246, -248, -2410: 24 VAC  
PBA-1206, -1208, -12010: 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible fire alarm control units. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
*Program Manager*